



- M= MOTOR STARTER OPERATING COIL.
- ① INTERLOCKING, INDICATING RELAY WITH REVERSIBLE N.O. OR N.C., 10 AMPS (CONTINUOUS) CONTACTS MOUNTED IN AN ADJACENT CABINET. PROVIDE (1) RELAY FOR EACH STARTER AND EACH STARTER SPACE.
- O OPERATING RELAY. LOCATE IN AN ADJACENT RELAY CABINET.
- "S1.S2 = TERM. FOR REMOTE LOCK-OUT STOP. PROVIDE JUMPER WHEN LOS'S ARE NOT REQUIRED ON DRAWINGS.
- O102 = TERM. FOR CONNECTION OF CONTROL CIRCUIT TO CAUSE MOTOR TO
- I_1 , I_2 =TERM. FOR INTERLOCKING AND INDICATING CIRCUITS WIRED TO TERMINAL BLOCK IN RELAY CABINET.

TYPICAL MOTOR STARTER DIAGRAM




NOTES: 1. FIRE ALARM PANEL SHALL BE PROGRAMMED TO CLOSE INDIVIDUAL FIRE/SMOKE DAMPERS USING AREA DETECTION IN ALARM CONDITION. 2. CONTROL RELAY MODULE AND CONTACTOR SHALL BE MOUNTED WITHIN 3' OF FIRE/SMOKE DAMPER PER NFPA 72, 6.15.2.1

WIRING DIAGRAM - F/S DAMPER




DETAIL - CONDUIT SUPPORT ON ROOF



NOTES: 1. SECURE FIXTURES TO T-BAR SYSTEM WITH (2) 1/8" DIAMETER ZINC PLATED SELF TAPPING "TEK" SCREWS AT EACH END. POINTED SHEET METAL SCREWS ARE NOT ACCEPTABLE. DRILL FIXTURES AND T-BAR RUNNER AS REQUIRED. LOCATE SUCH THAT SCREWS DO DO NOT INTERFERE WITH DOOR OPERATION.

DETAIL - TYPICAL LAY-IN FIXTURE MOUNTING



SURFACE MOUNTED FIXTURE

SYMBOL LIST

FLUORESCENT FIXTURE - SEE FIXTURE SCHEDULE FOR MOUNTING

CONDUIT RUN CONCEALED IN CEILING OR WALL, SEE NOTE #1

CONDUIT RUN UNDERGROUND OR UNDER FLOOR. NO CONDUIT SHALL BE INSTALLED IN

SIGNAL CABLE ROUTED THROUGH J-HOOKS ABOVE ACCESSIBLE CEILINGS.

EXISTING CONDUIT RUN

HOMERUN TO PANELBOARD OR RESPECTIVE TERMINAL

JUNCTION BOX - SIZE AS REQUIRED BY CODE

DISCONNECT SWITCH (F = FUSED)DUPLEX RECEPTACLE +18" (A = ABOVE COUNTER, T = IN TOE SPACE,

GFI = GROUND FAULT CIRCUIT INTERRUPTER TYPE)

SPECIAL RECEPTACLE, COORDINATE REQUIREMENTS WITH EQUIPMENT TO BE SERVED

MECHANICAL EQUIPMENT INSTALLED BY OTHERS, CONNECTED BY ELECTRICAL CONTRACTOR.

FIRE/SMOKE DAMPER FURNISHED BY MECHANICAL

FLAG REFERRING TO NUMBERED NOTE ON SAME SHEET

DEMOLITION NOTE

ABOVE COUNTER

ABOVE FINISHED FLOOR

C, CO CONDUIT, CONDUIT ONLY

EXISTING

G, GND GROUND

GROUND FAULT CIRCUIT INTERRUPTER

(N)

PROVISIONS FOR FUTURE BREAKER

UNLESS OTHERWISE NOTED VFD VARIABLE FREQUENCY DRIVE

WEATHER PROTECTED

NOTED ON DRAWINGS.

WALL AND USE CUT-IN BOXES.

NOTES:

1. NO CROSSBARS ON CONDUIT RUN INDICATES 3/4" CONDUIT, TWO #12 CONDUCTORS. CROSSBARS INDICATE NUMBER OF #12 CONDUCTORS IN CONDUIT. CONDUCTOR SIZE OTHER THAN #12

2. SYMBOLS FOR EXISTING ARE SHOWN THE SAME AS NEW EXCEPT DRAWN DASHED.

ELECTRICAL SCOPE DRAWINGS

THESE ELECTRICAL DRAWINGS INDICATE THE GENERAL SCOPE OF THE PROJECT IN TERMS OF ELECTRICAL DESIGN CONCEPT, MAJOR ELECTRICAL ELEMENTS, AND THE TYPE OF ELECTRICAL SYSTEMS. AS SCOPE DOCUMENTS, THESE DRAWINGS DO NOT NECESSARILY INDICATE OR DESCRIBE ALL WORK REQUIRED FOR FULL PERFORMANCE AND COMPLETION OF THE REQUIREMENTS. ON THE BASIS OF THE GENERAL SCOPE INDICATED OR DESCRIBED, THE CONTRACTOR SHALL FURNISH ALL ITEMS REQUIRED FOR THE PROPER EXECUTION AND COMPLETION OF THE WORK.

GENERAL NOTES

INFORMATION GIVEN CONCERNING EXISTING ELECTRICAL INSTALLATION IS AS EXACT AS COULD BE SECURED, BUT EXTREME ACCURACY IS NOT GUARANTEED. CONTRACTOR SHALL VISIT THE JOB SITE PRIOR TO BIDS AND SATISFY HIMSELF AS TO THE CONDITIONS UNDER WHICH THE WORK IS TO BE PERFORMED.

. EXISTING CIRCUITS AND SERVICES SHALL NOT BE INTERRUPTED EXCEPT BY SPECIFIC APPROVAL OF

THE OWNER. ALL SHUTDOWNS SHALL BE SCHEDULED WITH THE OWNER. 3. IN FININSHED SPACES, ALL INTERIOR CONDUIT SHALL BE RUN CONCEALED. FISH FLEX IN EXISTING

. REMOVE AND REPLACE (E) CEILING TILES AS NECESSARY TO INSTALL (N) RACEWAYS. PROVIDE (N) TILES TO REPLACE (E) WHERE (E) ARE DAMAGED BY WORK OF THIS CONTRACTOR. (N) TILES SHALL MATCH (E) AND BE APPROVED BY OWNER.

5. CEILING TILES (AND POSSIBLY GRID) WILL BE REMOVED BY DIV. 15 FOR REMOVAL AND INSTALLATION OF DUCTWORK AND EQUIPMENT. ELECTRICAL CONTRACTOR SHALL WORK CLOSELY TO INSURE THAT EXISTING ELECTRICAL FIXTURES, DEVICES, EQUIPMENT, CONDUIT AND WIRING ARE LEFT INTACT. WHERE (E) ELECTRICAL WORK MUST BE DISTURBED, ADJUST, REMOVE AND REPLACE OR OTHER WORK NEEDED TO ALLOW DIV. 15 CONTRACTOR TO COMPLETE HIS WORK.

CONSULTANTS:

3-5-15

1-26-15

10-27-14


100% CONSTRUCTION DOCUMENTS


CONSTRUCTION DOCUMENTS (60%)

VA FORM 08-6231

100% NOT FOR CONSTRUCTION SUBMITTAL

CHARLES A. MARTIN CAMA JOB #: 4592







Project No. 13-9111.00 SYMBOLS, NOTES AND DETAILS Approved: Project Director

VA REPLACE SURGERY EXHAUST SYSTEM, BLDG 1, 3RD FLR Location FRESNO, CA

Project Number Office of 570-13-211 Construction **Building Number** and Facilities Drawing Number Management E00

Department of Veterans Affairs

3-05-15

Checked

Dwg. of